



## **Boil Water Advisory Guidelines**

### **Retail Food Service Establishment Requirements**

**\*\*Please note that if you are unable to comply with these guidelines you must cease operations until the boil water advisory has been rescinded. \*\***

#### **Boiling Method:**

Boil water rapidly for 1-3 minutes. *Be sure to allow the water to cool before use.*

#### **Commercially bottled or boiled water **MUST** be used for the following:**

- All beverages such as coffee, tea or fountain drink dispensers.
- All ingredients in any food products.
- Consumable ice such as commercially packaged ice.
- Use a commercial hand sanitizer, bottled water or water that has been boiled 1-3 minutes for hand washing. Be sure boiled water is cooled before use.
- Washing and sanitizing food contact surfaces.
- Washing produce.
- Sanitizing solution for wiping cloths.
- All water used in the 3 compartment sink. Single-serve items and/or disposable utensils are best.

#### **The following can **NOT** be used during boil water advisories:**

- Carbonated fountain drink machines.
- Beverage "gun" dispensers.
- Machines that produce ice.
- Low-temperature/chemical sanitizing dishmachines.
- Self-serve bulk water dispensers

#### **Precautionary measures after boil water advisories have been lifted:**

- Flush the buildings water lines and clean faucet screens.
- Flush and sanitize all water-using fixtures and appliances of standing water, such as ice machines, beverage dispensers, hot water heaters, direct water source machines, etc. Replace water filters.
- Run ice machines through one cycle of ice production and discard the ice. Then clean and sanitize the bin.
- Clean and sanitize all fixtures, sinks, and equipment connected to water lines.

**A HEALTH DEPARTMENT REPRESENTATIVE DOES NOT NEED TO BE PRESENT IN THE ESTABLISHMENT FOR THESE GUIDELINES TO TAKE EFFECT. IT IS MANAGEMENT'S RESPONSIBILITY TO ENSURE THEY ARE OPERATING IN A SAFE MANNER, TO PROTECT THE PUBLIC'S HEALTH, AT ALL TIMES.**

**DeKalb County Board of Health**  
**Division of Environmental Health**  
445 Winn Way – Suite 320  
Decatur, GA 30030  
404.508.7900 • [www.dekalbhealth.net](http://www.dekalbhealth.net)